GENERSYS INC.
Generator Systems Maintenance & Repair

905-751-5549
www.genersys.ca
Info@genersys.ca

Monthly inspection, test, and maintenance requirements

No. 1	Complete system test (No. 2)							Signature	Date
Weekly items	Failure simulation	30% load test for 60 min	Transfer switches	Brush operation	Bearing seals	Auxiliary equipment	Exhaust condensate trap		
									Jan /
									Feb /
									Mar /
									Apr /
									May /
									Jun /
									Jul /
									Aug /
									Sep /
									Oct /
									Nov /
									Dec /

Instrument readings (No. 2(g))								Signature	Date
Oil pressure	Oil temp	Coolant temp	Battery charge	Volts	Amps	Hz			
									Jan /
									Feb /
									Mar /
									Apr /
									May /
									Jun /
									Jul /
									Aug /
									Sep /
									Oct /
									Nov /
									Dec /

GENERSYS INC.
Generator Systems Maintenance & Repair

905-751-5549
www.genersys.ca
Info@genersys.ca

Maintenance repairs and replacements

Date	Unit No.	Defects	Service notes	Signature